


HX - GAS SYSTEM

■ **PROVEN LOW FIRE START**



“HX” GAS SYSTEM SCHEMATIC
(As shown meets U. L. requirements)

APPLICATION

The “HX” gas system is used for on-off, proven low fire start control. It is commonly used on burners with 400 MBh to 5,000 MBh capacity and is used in conjunction with the “F4HX”, “F4VX” or “F4VTX” oil systems for combination gas-oil models.

DESCRIPTION

The “HX” system uses a motorized gas valve and a quick opening solenoid gas valve arrangement to control gas flow. Gas pressure is adjusted and maintained by a pressure regulator.

Combustion air available to the burner is controlled by connection of the air inlet louver to the motorized gas valve through a linkage arrangement.

The proven low fire start feature is obtained by the use of a micro-switch, mounted on the air inlet louver box, which proves electrically that the air louver is in the low fire start position.

OPERATING SEQUENCE

The burner motor starts on a call for heat by the operating control and the pre-purge cycle begins. The motorized valve is in the closed position, allowing low fire combustion air through the louver.

At the end of pre-purge, the micro-switch proves the low fire louver position, the ignition transformer is energized and the pilot valve opens, igniting the gas pilot.

The flame detector proves the flame and the safety shutoff gas valves open, slowly supplying gas to the orifices at the low fire rate, and the burner ignites in the low fire position.

The ignition transformer and pilot valve are de-energized.

The motorized gas valve continues to open, allowing the linkage to drive the air louver to the full open position and the burner goes to high fire.

When the operating control is satisfied, the gas valves close and the burner motor is switched off, causing the burner to shut down and await the next call for heat.